Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Jind
Email id: chemist.jnd@gmail.com Ph.No.01681-246354

TC-4072

Test Report

Memo No:-	:	1399	Date:-18.09.2026
Job Order No:-	:	PC22/9/2026	
Test Report No:-	:	JND/03563/9/2026	
Issued To:-	:	Rishikul Public Sr. Sec. School, Narwana Road, Jind	
Customer Reference No:-	:	Nil	Dated:-15.09.2026
Sample Description	:	Drinking Water	
Sample Type	:	Chemical Analysis	
Sample collected on dated	:	15.09.2026	
Sample Collected by	:	Party Self	
Sample received on dated	:	15.09.2026	
Sample Location	:	Rishikul Public Sr. Sec. School, Narwana Road, Jind	
Sample Quantity	:	2ltr	
Date of Analysis started	:	15.09.2026	
Dated of analysis completed	:	17.09.2026	
Issue Date	:	18.09.2026	

Environmental Conditions:- Temperature (°c) =26.4 & Humidity (%) =58

RESULTS

Sr. No.	Parameter	Protocol Used	Results	IS: 10500: 2012 (RA-2023)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1.	Taste	IS 3025(Part8): 2023	Agreeable	Agreeable		-------
2.	Odour	IS 3025(Part5): 2018	Agreeable	Agreeable		-------
3.	Colour	APHA 24th edition-2120-B	5.0	5	15	Hazen Unit
4.	Turbidity	APHA 24th edition -2130 B	0.29	1	5	NTU
5.	Total Dissolved Solids@180°c±2°c	APHA 24th edition -2540 C	175	500	2000	mg/L
6.	Total Hardness	APHA 24th edition -2340 C	38	200	600	mg/L
7.	Calcium (as Ca)	APHA 24th edition -3500-Ca B	5.61	75	200	mg/L
8.	Magnesium (as Mg)	APHA 24th edition -3500 Mg B	5.83	30	100	mg/L
9.	Total Alkalinity	APHA 24th edition - 2320 B	48	200	600	mg/L
10.	Chloride (as Cl)	APHA 24th edition -4500 Cl B	26.61	250	1000	mg/L
11.	Fluoride (as F)	APHA 24th edition -4500- F C	0.25	1.0	1.5	mg/L
12.	Sulphate (as So_4)	APHA 24th edition -4500-So_4E	33	200	400	mg/L
13.	Nitrate (as NO3)	APHA 24th edition -4500-No_3D	<0.5	45	45	mg/L
14.	Iron (as Fe)	APHA24th edition-3500-Fe B	<0.02	1.0	1.0	mg/L
15.	pH @25°c	APHA 24th edition -4500-H^+ B	7.19	6.5 to 8.5	No relaxation	-------

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Jind. Reliability of sample lies with the sender.
- Sample not collected by this Laboratory.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Reviewed & Approved by

(Virender Singh)
Authorized Signatory/Chemist
PHED Water Testing Laboratory, Jind

Sample analyzed by: Sumit

END OF TEST REPORT

HEALTH DEPARTMENT DISTRICT JIND

Hygienic Certificate

Certified that Dy. Civil Surgeon (Health) O/o Civil Surgeon Jind inspected the premises on 24.09.2026 and found the hygienic and sanitation condition of **Rishikul Public Sr.Sec.School Near Radha Soami Satsang Bhawan, Narwana Road Jind**. satisfactory for the year **2026-27.**

Memo No.Hygienic/CSJind/2026-27/85
Dated : 24/9/2026

Dy. Civil Surgeon (Health)
For Civil Surgeon Jind.
24/9/26